

Name _____

Date _____

Instructor _____

Hazard Recognition: Fire Safety & Prevention Pre-Post Test Answer Key

1. All exit doors must open freely when the building is occupied.
True or False

2. What is the proper fire extinguisher type for a gasoline or diesel fuel fire?
 - a. Class A
 - b. **Class B**
 - c. Class C
 - d. Class D
 - e. All of the above

3. What is the proper fire extinguisher type for paper, wood or cardboard fires?
 - a. **Class A**
 - b. Class B
 - c. Class C
 - d. Class D
 - e. All of the above

4. Oxygen and propane cylinders can be stored together.
True or **False**

5. Fire doors can be propped or blocked open when the building is occupied.
True or **False**

6. Exit pathways only need to be clear and accessible during business hours.

True or **False**

7. Always approach fires...

- a. From a distance
- b. Upwind
- c. With a means of escape behind you
- d. **All of the above**

8. OSHA only requires fire prevention plan training for employees upon hiring or assignment to a new position.

True or **False**

9. What does the acronym RACE stand for?

- a. **Remove all victims, Alert responders, Confine the fire, Extinguish the fire**
- b. Remove all belongings, Ask for help, Catch the fire, Extinguish the fire
- c. Run from the fire, Alert the neighbors, Call for backup, Extinguish the fire
- d. Remove all victims, Alert responders, Catch the wind, Extinguish the fire

10. What does OSHA require as part of a fire prevention plan?

- a. A list of all major hazards
- b. Name or job title of employees responsible for controlling fuel source hazards
- c. Type of fire protection equipment necessary to control each major hazard
- d. **All of the above**